

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Recessed luminaire

Name and address of the applicant

Thorn Lighting Ltd  
Durhamgate, Spennymoor,  
County Durham, DL16 6HL, United Kingdom

Name and address of the manufacturer

Thorn Lighting Ltd  
Durhamgate, Spennymoor,  
County Durham, DL16 6HL, United Kingdom

Name and address of the factory

Thorn Lighting Ltd  
Durhamgate, Spennymoor,  
County Durham, DL16 6HL, United Kingdom*Note: When more than one factory, please report on page 2* Additional Information on page 2

Ratings and principal characteristics

220-240 V, 50-60 Hz; IP20/IP44; Cl.II; LED

Trademark (if any)

THORN

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Series Omega LED,  
see product range on page 6 of test report.

Additional information (if necessary may also be reported on page 2)

Classified within limits of RG0 (exempt group) according to IEC 62471:2006.

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014  
IEC 60598-2-2:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

TR 85175-0025-01

This CB Test Certificate is issued by the National Certification Body

**AUSTRIAN ELECTROTECHNICAL ASSOCIATION**Kahlenberger Str. 2A  
1190 Wien, Austria  
Digitally signed by W. Martin  
Email=w.martin@ove.at  
Signature: Dipl.-Ing. W. Martin

Date: 2017-05-24

ZVR: 327279890 | DVR: 1055887