

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST SCHEME

## CB TEST CERTIFICATE

Product	Emergency Luminaires
Name and address of the applicant	Tridonic UK limited House of Light, Butchers Race Green Lane Industrial Estate, Spennymoor County Durham, DL16 6JE, United Kingdom
Name and address of the manufacturer	As above
Name and address of the factory	As above
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Input 220-240V 50/60 Hz ta 5°C ... 30°C
Trademark (if any)	TRIDONIC & THORN
Model / Type Refs.	See page 2
Additional information (if necessary may also be reported on page 2)	CENELEC group differences considered
A sample of the product was tested and found to be in conformity with	<b>Publication</b> IEC 60598-1:2014 IEC 60598-2-2:2011 IEC 60598-2-22:2014
As shown in the Test Report Ref. No. which forms part of this Certificate	New report 8876592 Original report 8575610

This CB Test Certificate is issued by the National Certification Body



BSI, Kitemark Court  
Davy Avenue, Knowlhill  
Milton Keynes, MK5 8PP  
United Kingdom.  
Phone +44 (0)8450 809000  
Signature:

Date: 13 December 2017



Original issue date 7 June 2017

Mark Littlejohns Certification manager

# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST SCHEME

The type references covered by this certificate are as listed below:

Model	Article No.	Operation	Test function	Rated duration
EM R2A BASIC NM 111 2W	89800534	Non-maintained	N/A	1 Hr
EM R2A BASIC M 111 2W	89800535	Maintained	N/A	1 Hr
EM R2A BASIC NM 131 1W	89800533	Non-maintained	N/A	3 Hrs
EM R2A BASIC NM 132 2W	89800536	Non-maintained	N/A	3 Hrs
EM R2A BASIC M 132 2W	89800537	Maintained	N/A	3 Hrs
EM R2A ST NM 111 2W	89800538	Non-maintained	Self-test	1 Hr
EM R2A ST M 111 2W	89800539	Maintained	Self-test	1 Hr
EM R2A ST NM 132 2W	89800540	Non-maintained	Self-test	3 Hrs
EM R2A ST M 132 2W	89800541	Maintained	Self-test	3 hrs
EM R2A PRO NM 111 2W	89800542	Non-maintained	DALI	1 Hr
EM R2A PRO M 111 2W	89800543	Maintained	DALI	1 Hr
EM R2A PRO NM 122 2W	89800546	Non-maintained	DALI	2 Hrs
EM R2A PRO M 122 2W	89800547	Maintained	DALI	2 hrs
EM R2A PRO NM 132 2W	89800544	Non-maintained	DALI	3 Hrs
EM R2A PRO M 132 2W	89800545	Maintained	DALI	3 hrs

## Voyager range of self-contained recessed emergency luminaires

Type	Article No.	Operation	Test function	Rated duration
VOYAGER FIT MRC E3T NM	96629567	Non-maintained	Self-test	3 Hrs
VOYAGER FIT MRC E3 NM	96629566	Non-maintained	N/A	3 Hrs
VOYAGER FIT MRC E3D NM	96629568	Non-maintained	DALI	3 Hrs
VOYAGER FIT MRC E3D M	96630056	Maintained	DALI	3 Hrs

The luminaires can be supplied with the following lens options 1. Anti-panic (A), 2. Escape route (E), 3. Spot (S)

This CB Test Certificate is issued by the National Certification Body



BSI, Kitemark Court,  
Davy Avenue, Milton Keynes,  
MK5 8PP. United Kingdom.  
Phone +44 (0)8450 809000

Date: 13 December 2017

Signature:



Original issue date 7 June 2017

Mark Littlejohns Certification Manager