

AT 3896

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Ceiling recessed LED luminaire

Name and address of the applicant

Thorn Lighting Ltd Durhamgate, Spennymoor, County Durham, DL16 6HL, United Kingdom

Name and address of the manufacturer

Thorn Lighting Ltd Durhamgate, Spennymoor, County Durham, DL16 6HL, United Kingdom

Name and address of the factory

Thorn Lighting Ltd Durhamgate, Spennymoor, County Durham, DL16 6HL, United Kingdom

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

AC 220-240 V; CI.I; IP20/IP44; LED.

Ratings and principal characteristics

Trademark (if any) **THORN**

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Series IQ WAVE, see page 5 of test report.

Additional information (if necessary may also be reported on page 2)

Classified within limits of risk group 1 (low risk) according to IEC 62471:2006.

A sample of the product was tested and found to be in conformity with

Additional Information on page 2

As shown in the Test Report Ref. No. which

IEC 60598-1:2014 IEC 60598-2-2:2011

TR 85175-0024-01 forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body



Österreichischer Verband für Elektrotechnik

Testing & Certification A, 1190 Wien, Austria Kahlenberger Str

Date: 2018-03-16

Digitally signed by W. Martin Email=w.martin@ove.at ature: Dipl.-Ing. W. Martin